



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

December 18, 2013

VIEGA LLC
DAVID OVERBY
4240 N COTTONWOOD LANE
PLYMOUTH MN 55441

VIEGA LLC
DAVID OVERBY
301 N MAIN 9TH FLOOR
WICHITA KS 67202

Re: Description: PIPES AND FITTINGS, STAINLESS STEEL
Manufacturer: VIEGA LLC
Product Name: VIEGA PROPRESS STAINLESS 316 PIPE AND FITTINGS
Model Number(s): 1/2 - 4" USING EPDM ELASTOMERIC SEALS
Product File No: 20130363

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 381.40 (8) & table SPS 384.30-8 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2018.

This approval supersedes the approval issued on May 17, 2008 under product file number 20080565.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product because the design of the product meets the intent of s. SPS 384.40 (8), Wis. Adm. Code that requires mechanical compression type joints for water supply which use flexible elastomeric seals to be suitable for potable water. The intent of the code is met since this product provides an acceptable elastomeric seal.
- This product shall be installed in accordance to manufacture's specifications.
- Maximum Allowable Load for this product will be Table 382.40-4 found in the Wisconsin Administrative Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail